
REPORT ON ENERGY AUDIT

SHRI RAMSWAROOP MEMORIAL GROUP OF PROFESSIONAL COLLEGES



Tiwariganj, Faizabad Road,

Lucknow (UP) - 226028

Submitted by

Er Ashoutosh Kumar

B.E., M.Tech., MBA

Certified Energy Auditor EA-549

Retd. Executive Director UP Power Corporation

**SHRI RAMSWAROOP MEMORIAL GROUP OF PROFESSIONAL
COLLEGES (SRMGPC)**

Energy Audit Committee

Sr. No.	Name	Designation	Role
1	Dr VK Singh	Director (Admin)	Coordinator
2	Ashoutosh Kumar	Audit Agency	Engineer & Certified Energy Auditor
3	Siddharth Srivastava	Audit Agency	Assistant

ENERGY AUDIT CERTIFICATE

This is to certify that Walk-Through Energy Audit for Shri Ramswaroop Memorial Group of Professional Colleges (SRMGPC), Tiwariganj, Faizabad Road, Lucknow 226028 has been conducted in July 2021 to assess energy costs, availability, and reliability of supply of energy, energy conservation technologies and to explore energy saving avenues to reduce energy consumption.

Place: Lucknow

Date: Sept 12, 2021

Dr V. K Singh

Ashoutosh Kumar

Director Administration, SRMGPC

Certified Energy Auditor

Table of Contents

ACKNOWLEDGEMENTS.....	5
Executive Summary.....	6-8
CHAPTER 1	9
INTRODUCTION TO ENERGY AUDIT	
General.....	
Scope of Work, Methodology and Approach.....	
Approach to Energy Audit.....	
Energy Audit.....	
Energy Audit Methodology	
Chapter 2.....	10
About SRMGPC	
CHAPTER 3	11-17
HISTORICAL DATA ANALYSIS	11
Study of Variation of Monthly Units consumption & Power Factor:	11-12
Monthly Units consumption	13
Maximum Recorded Demand/ Demand Charges	14-15
Sanctioned Load Vs Maximum recorded demand.....	16
General Observations based on Electricity Bill	17
Chapter 4.....	18-20
Details of Energy consuming Equipment's Installed.....	188
Lighting Fixtures.....	188
Fans	19
Air Conditioners	19
Other equipment	20
Chapter 5.....	21
STUDY OF ELECTRICAL SYSTEMS.....	2121
Electricity Connection	21
Diesel Generators	21
Chapter 6.....	22-29
Analysis of Data & Saving Avenues	22
Study of Utility Bill.....	22
Study of Equipment/Appliances	22-29
Chapter 7.....	30
Carbon Emission.....	
Chapter 8.....	31
General Recommendations.....	
Chapter 9 Way Forward.....	32

ACKNOWLEDGEMENTS

An energy audit study is a joint exercise of consultant and organization to account & contain energy usage without sacrificing the purpose of usage of energy. The contribution of organization's team is equally important in this endeavor.

We take this opportunity to convey our sincere thanks and gratitude for the kind cooperation extended by the management and staff of Shri Ramswaroop Memorial Group Of Professional Colleges and acknowledge the contribution of the following dignitaries and site engineering personnel for providing timely assistance and guiding the team for conduct of this vital energy audit study.

Er. Pankaj Agrawal – Founder & Executive Director

Prof (Dr) Bhavesh Kumar Chauhan – Group Director

Dr V. K. Singh - Director Administration

We are sure; this report will be quite useful for Energy Management to intensify and implement energy conservation measures in the organization and achieve desired savings.

We appreciate the keen interest taken by the management to save precious energy in the interest of the organization as well as our Nation.

Executive Summary

The objective of the audit was to study the energy consumption pattern of the facility, identify the areas where potential for energy/cost saving exists and prepare proposals for energy/cost saving along with investment and payback periods.



The salient observations and recommendations are given below. Electricity bill of SRMGPC monthly electricity bill varies from maximum Rs1673525/- to minimum Rs 540410/-.

SRMGPC uses energy in the following forms:

- a. Electricity from MVVNL
 - b. High Speed Diesel (HSD)
 - c. LPG in Hostel Mess
-
1. Electrical energy is used for various applications, like:
 - a. Computers
 - b. Lighting
 - c. Air-Conditioning
 - d. Fans
 - e. Other Lab Equipment
 - f. Geysers in Hostel
 - g. Water lifting submersible Pumps
 - h. Deep Freezers & Refrigerators
 - i. Motors of Various Lab Equipment's
 - j. Water Coolers
 - k. Motors for Pumps of Sewage Treatment Plant
 2. The average cost of energy is around Rs. 8,35,194/Month.
 3. Area Of Campus

Area of Campus in Square Metres	
Total area covered at ground	15598
Round and open area	35676
Total ground area of campus	51274
Total floor area	60606
Ground coverage	$15598 \times 100 / 60606 = 25.73\%$

4. The Specific Energy Consumption (SEC) is the ratio of energy required per square meter. In this case the SEC is evaluated as electrical units consumed per square meter of area. SEC is calculated and plotted as below.



Presently maximum specific energy consumption with summer load in normal functioning of institute is around 2.5 and we should try to achieve around 2.0 in one year and finally settle for 1.75.

5. After the analysis of data and equipments installed, we propose herewith following Energy Efficiency Improvement measures.

Sr. No	Recommendations	Monthly Savings (Rs.)	Annual Saving Potential (Rs.)	Estimated Investment (Rs.)	Payback Period (Months)	Remarks
1	By reducing Contracted Demand to 700KVA	79,000	9,48,000	0	Immediate	Without Delay
2	By Installing IGBT based device for reactive power management	45,000	5,10,000	5,00,000	12	Medium cost- Medium Payback
3	Depositing Electricity Bill within due date	4,000	48,000	0	Immediate	Without Delay
4	Replacing tube lights with choke by LED Tube lights	1,16,600	14,00,000	4,46,800	4	Medium cost- Short Payback
5	By replacing Rheostatic regulators by electronic regulators 1500 Nos	50,000	6,19,000	3,00,000	6	Low cost –Short Payback
6	By Replacing 25% ie 575 Nos old and repaired fans by energy efficient fans every year	25,000	2,93,250	6,90,000	28	Medium cost – Medium Payback
7	By providing Solar water geysers in Hostels and Mess	1,00,000	12,24,700	24,95,000	24	Medium cost- Medium Payback
8	By Replacing 200 Nos Desktops by Laptops	72,250	8,67,000	50,00,000	72	Heavy Cost- Long Payback
9	Replacing repairable / defective 36 Nos AC by Energy Efficient 3 Star AC		4,90,000	10,80,000	26	Medium Investment- Medium payback
10	Replacing 40 Nos AC w/o star by Energy Efficient 3 Star AC every year		5,44,000	12,00,000	26	Medium Investment- Medium payback
11	By Providing 250 KW Solar Power plant		24,00,000	100,00,000	24	Heavy Investment- Medium Payback
	Total		93,00,000	2,17,00,000	28	

NOTE: Total savings is estimated at 93 Lakhs which is 31 % of the total energy cost with an overall payback period of 5.78 Years

CHAPTER 1

INTRODUCTION TO ENERGY AUDIT

General

The Shri Ramswaroop Memorial Group of Professional Colleges entrusted the work of conducting a Walkthrough Energy Audit of campus at Tiwariganj, Lucknow with the main objectives as below:

- a. To study the present pattern of energy consumption
- b. To identify potential areas for energy optimization
- c. To recommend energy conservation proposals with cost benefit analysis.

Scope of Work, Methodology and Approach

Scope of work and methodology were as per the proposal. While undertaking data collection, field trials and their analysis, due care was always taken to avoid abnormal situations so as to generate normal / representative pattern of energy consumption at the facility.

Approach to Energy Audit

We focused our attention on energy management and optimization of energy efficiency of the systems, sub systems and equipments. The key to such performance evaluation lies in the sound knowledge of performance of equipments and system as a whole.

Energy Audit

The objective of Energy Audit is to balance the total energy inputs with its use and to identify the energy conservation opportunities in the stream.

Energy Audit also gives focused attention to energy cost and cost involved in achieving higher performance with technical and financial analysis. The best alternative is selected on financial analysis basis.

Energy Audit Methodology

Energy Audit Study is divided into following three steps:

A. Historical Data Analysis

The historical data analysis involves establishment of energy consumption pattern to establish base line data on energy consumption and its variation with change in different months of year.

B. Identification and evaluation of Energy Conservation Opportunities

This step involves evaluation of energy conservation opportunities identified during the energy audit. It gives potential of energy saving and investment required to implement the proposed modifications with payback period. All recommendations for reducing losses in the system are backed with its cost benefit analysis.

Chapter 2

About SRMGPC

Sr. No.	Particulars	Details
1	Name of the Institute	Shri Ramswaroop Memorial Group of Professional Colleges
2	Address	Tiwariganj, Faizabad Road Lucknow-226028
3	Year of Establishment	1999
4	Courses Offered	B. Tech. Computer Sciences & Engineering Artificial Intelligence & Machine Learning Information Technology Electrical & Electronics Engineering Electronics & Communication Engineering Mechanical Engineering Electrical Engineering Civil Engineering M.Tech. Computer Science & Engineering Civil Engineering Environmental Engineering Master Of Business Administration Master of Computer Application
5	Affiliation	Dr. A.P.J. Abdul Kalam Technical University Lucknow
6	Total Building Carpet Area	60606 Sq meter

CHAPTER 3

HISTORICAL DATA ANALYSIS



Study of Variation of Monthly Units consumption & Power Factor:

In this Chapter, we study the details of last 24 months Electricity Bills. Main points of study are as follows.

Month	KVAH	KWH	Diff	Power Factor	SEC KWH/sq m	Month	Power Factor	SEC KWH/sq m
Jun-19	144807	141982	2825	0.980	2.389	Aug-17	0.950	1.29
Jul-19	85418	82852	2566	0.970	1.409	Sep-17	0.969	2.26
Aug-19	92012	87601	4411	0.952	1.518	Oct-17	0.971	2.50
Sep-19	146774	139216	7558	0.949	2.422	Nov-17	0.966	2.02
Oct-19	128476	124058	4418	0.966	2.120	Dec-17	0.941	1.35
Nov-19	88205	85280	2925	0.967	1.455	Jan-18	0.926	1.25
Dec-19	61774	59718	2056	0.967	1.019	Feb-18	0.927	1.05
Jan-20	60448	58297	2151	0.964	0.997	Mar-18	0.935	1.12
Feb-20	60765	58568	2197	0.964	1.003	Apr-18	0.957	1.66
Mar-20	60704	58454	2250	0.963	1.002	May-18	0.973	2.08
Apr-20	37055	33567	3488	0.906	0.611	Jun-18	0.975	2.46
May-20	25966	22293	3673	0.859	0.428	Jul-18	0.965	1.40
Jun-20	35957	33737	2220	0.938	0.593	Aug-18	0.960	1.40
Jul-20	68641	64844	3797	0.945	1.133	Sep-18	0.970	2.29
Aug-20	58432	52730	5702	0.902	0.964	Oct-18	0.962	2.44
Sep-20	41953	37018	4935	0.882	0.692	Nov-18	0.971	2.06
Oct-20	59483	54179	5304	0.911	0.981	Dec-18	0.926	0.97
Nov-20	48523	43076	5447	0.888	0.801	Jan-19	0.934	0.98
Dec-20	28606	22544	6062	0.788	0.472	Feb-19	0.927	0.91
Jan-21	29309	23617	5692	0.806	0.484	Mar-19	0.944	0.94
Feb-21	32736	27195	5541	0.831	0.540	Apr-19	0.934	1.10
Mar-21	40083	33841	6242	0.844	0.661	May-19	0.982	1.85
Apr-21	52307.4	46399	5908	0.887	0.863			
May-21	22287	21744	543	0.976	0.368			
Total	1510721	1412810	97911					
	% Units Paid Extra		6.94					

Table: Unit Consumption Specific Energy Consumption & Power Factor

Variation of Power factor



The Power Factor (KWH/KVAH) is a measure to reduce the utility power bill. Most utility bills are based on KVAR usage. Difference between KWH and KVAH is loss due to reactive power generated internally. A good Power Factor provides a better voltage, reducing the pressure on electrical distribution network, reducing cable heating, cable over loading and cable losses, reducing over loadings of control gears and switchgears etc. Above all good power factor indicates efficiency of electrical energy utilization.

Reactive power management in SRMGPC is being done through AEC make 398 KVAR APFC panel and voltage is being maintained with the help of 350KVA Servo stabilizer.

Though power factor is being maintained normally in range of .98 to 0.788 but due to lack of effective and proper reactive power management especially in low load period SRMGPC has paid 97911 units ie Rs 8.5



Lakhs extra during last 24 months' time. It is mainly due to limitation of APFC and frequent outing of contactors and capacitors decay.

During low load period i.e., less than 25 % load, APFC does work so reactive power generated at low load remained uncompensated. Further transformer remained energized throughout and reactive power generated remains uncompensated as sensing CT of APFC is placed towards LT side of transformer.

Now hi-tech devices such as IGBT based compensators are available wherein sensing is being done from HT of transformer by which compensation of reactive power generated from transformer as well as during low load period can be efficiently done which in turn can take care of 90% of present KVAH and KWH unit difference.

Installing IGBT based device will substantially improve PF and will result in more saving.

Monthly Units consumption




There is very large variation in energy usage over period under study, from max 146774 to min 22287 units which is obvious due to seasonal change but sharp decay from April 20 onwards is due to suspension of activities on account of corona.

Maximum Recorded Demand/ Demand Charges


There is very large variation in maximum recorded monthly demand over period under study, from max 692 to min 49 units which is obvious due to seasonal change but sharp decay from April 20 onwards is owing to suspension of activities on account of corona.

Paid Month	Max Demand in KVA	PF	Present Demand charges Paid	Demand Charges Rate (Rs)	Demand Charges with 700KVA	Saving in Demand Charges	Late Payment Penalty Paid	Month	Max Demand KVA
Jun-19	588	0.980	283500	400	235200	48300	4727	Aug-17	487
Jul-19	599	0.970	283500		239600	43900	4953	Sep-17	631
Aug-19	571	0.952	283500		228400	55100	4414	Oct-17	692
Sep-19	663	0.949	283500		265200	18300	4075	Nov-17	672
Oct-19	689	0.966	297575	420	289380	8195	6677	Dec-17	305
Nov-19	477	0.967	304762	430	225750	79012	3037	Jan-18	195
Dec-19	204	0.967	304762		225750	79012	3449	Feb-18	210
Jan-20	182	0.964	304762		225750	79012	5418	Mar-18	207
Feb-20	194	0.964	304762		225750	79012		Apr-18	424
Mar-20	181	0.963	304762		225750	79012	5361	May-18	588
Apr-20	213	0.906	609524		451500	158024		Jun-18	571
May-20	49	0.859						Jul-18	541
Jun-20	175	0.938	304762		225750	79012	18752	Aug-18	458
Jul-20	372	0.945	304762		225750	79012	4925	Sep-18	630
Aug-20	270	0.902	304762		225750	79012	529	Oct-18	631
Sep-20	168	0.882	304762		225750	79012	2224	Nov-18	622
Oct-20	278	0.911	304762		225750	79012	2598	Dec-18	275
Nov-20	204	0.888	304762		225750	79012	3147	Jan-19	156
Dec-20	77	0.788	304762		225750	79012	2420	Feb-19	172
Jan-21	73	0.806	304762		225750	79012	1528	Mar-19	192
Feb-21	94	0.831	304762		225750	79012	1552	Apr-19	294
Mar-21	125	0.844	304762	225750	79012	2238	May-19	553	
Apr-21	195	0.887	304762	225750	79012	1807			
May-21		0.976	304762	225750	79012	5798			
Total Excess Demand Charges & Late Payment Surcharge						1675023	89629		


Charges with Present Demand/Reduced Demand/ Excess Demand Paid



Demand in KVA from Aug 17 to May 19



Demand in KVA from Jun 19 to Apr 21



Sanctioned Load Vs Maximum recorded demand

From above table it is very much clear that in last two years recorded monthly demand has never gone beyond 75% of sanctioned load. Billable minimum demand charge is 75% of sanctioned load or actual in case it is above 75%.

For specific purpose to evaluate and recommend reduction in contracted demand, maximum demand attained , study of further period from Aug 17 to May 19 was done. Meaning thereby in total period of 40 months ie Aug 17 – May 21 , maximum recorded demand is 692 KVA in month of Oct 17. So safely contracted demand can be reduced to 700 KVA means reduction of 250 KVA.

So, if demand before period under study has been in same range it will be advisable to reduce to 700 KVA which will result in monthly saving of Rs 79000/-. From above table it evident that had load reduction been done earlier it would have resulted in saving of Rs 16.75 Lakhs in last two years alone and would have further saved Rs 12.64 if period from Aug 17 to May 19 also considered ie total more than 30 lakhs extra.

Apart from above SRMGPC has paid Rs 89629 / extra due to late payment of bills.

General Observations based on Electricity Bill

1. For SRMGPC Campus the Contract Demand (CD) is 944 kVA and minimum billing Demand is 75% of the Contract Demand (709 KVA) or the 75% of actual recorded Demand whichever is higher. Since, the MD recorded in last 24 months is only 689 KVA, contacted demand can be reduced to 700 KVA.
2. The average electricity cost is Rs. 14.99 considering the last 24 months consumption and amount paid.
3. Average monthly Power Factor is maintained near 0.980, can be further improved by more than 1%
4. Rs 89629/- has been extra in form of late payment surcharge.

Chapter 4

Details of Energy consuming Equipment's Installed

4.1 Lighting Fixtures

Sr. No.	Place of Installation	Tube with Choke		Tube LED		LED Bulbs		Down Lights		Streetlights		
		No	Watt @50	No	Watt @18	No	Watt	No	Watt	No	Watt @	Watt
1	A Block	114	5700	28	504	62	1426	304	4222	48	60	2880
2	B Block	176	8800	6	108					6	170	1020
3	C Block	265	13250	19	342							
4	D Block	240	12000	7	126	12	84	10	240			
5	E Block	157	7850	219	3942	4	28	18	432			
6	F Block	149	7450	29	522			48	624			
7	G Block	311	15550	105	1890							
8	CV Raman Hostel	119	5950	32	576							
9	RK Hostel	168	8400	53	954							
10	Saraswati Hostel	406	20300	60	1080							
11	Boys Mess	40	2000	11	198							
12	Canteen	5	250	8	144							
13		45	2250	19	342							
14	Workshop, Gym, Store	139	6950		0							
Total		2334	116700	596	10728	78	1538	1538	5518	54		3900
Grand Total									138384			
									Say 138.38 KW			

4.2 Fans

Sl No	Place of Installation	Fans		Wall Fan	
		No	Watt @80	No	Watt @70W
1	A Block	127	10160	40	2800
2	B Block	191	15280		0
3	C Block	237	18960		0
4	D Block	213	17040	1	70
5	E Block	134	10720		0
6	F Block	145	11600	4	280
7	G Block	418	33440		0
8	CV Raman Hostel	193	15440		0
9	RK Hostel	203	16240		
10	Saraswati Hostel	417	33360		
11	Boys Mess	48	3840		
12	Canteen	12	960		
13	Workshop, Gym, Store etc.	99	960		0
Total		2338	188000	45	3150
Grand Total					191150
			Say		190 KW

4.3 Air Conditioners

As per ratings provided total tonnage of ACs installed is 428.5 Ton.

Sl. No.	Tonnage	Numbers	@ Watt	Total Watt
1	1.5T 3Star	36	1500	54000
2	1.5T W/o Star	213	2500	532500
3	1.0T W/o Star	08	2000	16000
4	5 T W/o Star	08	7000	56000
Total			658500 say	658 KW

4.4 Other equipment

A. Geyser @2000W			
Sr. No.	Place of Installation	No	Watt
1	CV Raman Hostel	14	42000
2	RK Hostel	16	48000
3	Saraswati Hostel	24	72000
4	Boys Mess	1	3000
Total		55	165000
B. Exhaust Fan			
1	18" Fan @200W	18	3700
2	12" Fan @100W	12	1200
Total		30	4900
C. Water Cooler 150 Lts @1780 W		41	72980
1	Desktop @180 W	972	174960
2	Laptop @30 watt	11	330
3	Server	1	1000
Total		16290	
E. Heavy Duty Printers/Copiers @1 KW		17	17000
		23	4600
G. Submersible Pumps			
1	3 HP	1	2200
2	1.5 HP	14	14000
			16200
H. Deep Freezers/ Fridge @276 Watt		12	3312
1	AC Phase Motor Lab Total 52 HP	20	38792
2	Lathe M/C 25.5 HP	22	19023
3	Hydraulic M/c Lab 12.5 HP	3	9325
4	Civil lab & Filter Pump STP @5 HP	3	11190
5	Garbage Pump @3 HP	1	746
6	Air Blower @7.5 HP	2	11190
7	2 HP Motor	8	5968
			96234
Grand Total		556516 say 557 KW	

Total Connected Load: (4.1 to 4.4 above) = 138+190+658+557 say 1543 KW

Chapter 5

STUDY OF ELECTRICAL SYSTEMS

SRMGPC has mainly two sources of Electricity Supply:

Electricity Connection

SRMGPC is getting power from Madhyanchal Vidyut Vitaran Nigam Ltd against A/c no 4217593000 with sanctioned load of 944 KVA under HV1/H11 under EUDD Chinhath Lucknow through 1250KVA, 11/0.4 KV transformer.

Diesel Generators

For back power SRMGPC has two Cummins India make diesel generators of 600 & 250 KVA capacity.

Annual consumption of diesel is 9400 Lts and yearly running hours is 135 Hrs. Annual cost of Diesel is approximately 7.0 Lakhs i.e. Rs 58750/per month.

Sr. No.	Details of electricity Demand	Tariff	HV-2/H21T
1	Sanctioned Demand	944	kVA
2	Minimum Billable Demand	708	kVA
3	Recorded Maximum Demand	692	kVA

Chapter 6

Analysis of Data & Saving Avenues

Based on detailed discussion, analysis of data in chapter 4 above following conclusions has been arrived.

Study of Utility Bill

- A. Demand Charges: As it is evident from above table and discussed in detail at SI No 4.2 that demand has never reached even to level of minimum billable demand of 708 KVA. SRMGPC has paid Rs 16.75 Lakhs extra as demand charges which could have been saved by reducing sanctioned demand to 700 KVA. Reducing sanctioned demand to 700KVA will result in monthly saving of Rs 79000/.
- B. Power Factor: For Reactive power management AEC make 398 KVAR APFC panel and for voltage regulation 350KVA Servo stabilizers are installed. Power factor during period under study varied from 0.988 to 0.788 and total 97911 Units i.e., Rs 8,82,000/- have been paid extra. Though PF is maintained quite efficiently but it can be seen from table of PF that with less consumption PF drops as during low load period APFC ceases to work due to its inherent limitation. Further APFC uses Capacitors and Contractors which its performance is affected on account of periodic de-rating of capacitors and damage to contractors. With advent of IGBT based solid state devices with sensing from HT side of transformer PF can be further improved. By implementing this technology PF can be further improved and this will save around 45000/ per month i.e., Rs 5.1 Lakhs per annum. Investment around Rs 5.0 Lakhs, payback period 12 months.
- C. Late Payment Surcharge: By paying monthly electricity bills within due date an average saving of Rs 4000/ per month can be achieved.

Study of Equipment/Appliances

Lighting equipment

As per 5.1 there are 2234 Nos of 4' Tube light with magnetic choke and only 596 Nos 18 W LED tube lights. Tube with magnetic chokes should be replaced with LED tube lights which will result in saving as follows.

Tubes with magnetic chokes- 2234 Nos

Wattage of each - 50 watts

Total Monthly electricity consumption= $2234 \times 50 \times 8 \times 30 \times 0.8 / 1000 = \mathbf{21446 \text{ KWH}}$

With LED tubes of 18W consumption= $2234 \times 18 \times 8 \times 30 \times 0.8 / 1000 = \mathbf{7721 \text{ KWH}}$

Saving in units = $21446 - 7721 = \mathbf{13725 \text{ KWH}}$

Monthly Saving in Rs = $9436 \times 8.5 = 116660/-$

Cost of replacement @ Rs 250/- = $2234 \times 200 = 446800$

Payback period = $446800 / 116660 = 3.82$ Months

In above calculation unit rate has been taken @Rs 8.5/ unit, switch on time of 8 hrs and diversity factor of 80%.

Ceiling Fan

There are a total 2338 ceiling fans installed in campus more than 50% of them are fitted with rheostatic regulators and almost all fans are regular fans. Saving in ceiling fans can be achieved in two ways

a. By replacing all rheostatic regulators by electronic regulators

Out of total 2338 fans approximately 1500 fans are still operating with rheostatic regulators or regulators are not working. There is considerable loss due to use of rheostatic regulator. Further using fan without regulator causes energy loss as power drawn by fan varies with speed.

A case study with comparative performance of both types regulators are tabulated below, wherein it is evident that saving % is maximum at lowest speed and same keep on decreasing with increase in speed. There will be an average reduction in energy consumption by 27 % with an electronic type of regulator as against a conventional type regulator.

Regulator Position	With Conventional Regulator		With Electronic Regulator		Relative Energy Saving %
	Watt	Energy Saving %	Watt	Energy Saving %	
1	50	32	28.4	61.4	43.2
2	54	26.5	37.5	49.0	30.5
3	60.5	17.7	47.5	35.4	21.5
4	65.3	11.1	57.3	22.0	12.2
5	75.0	0	75.0	0	0

Saving Economics: Assuming that ceiling fan is operated for 12 hrs/day, 200 days per year and saving achieved is 27% in energy consumption:

Annual Energy Consumed by one ceiling fan w/o regulator = Annual Cost of Energy Consumed by one ceiling fan w/o regulator = $75 \times 12 \times 200 \times 8.5 = \text{Rs } 1530$

Annual cost of energy saved for one ceiling fan = $1530 \times 0.27 = \text{Rs } 413/\text{year}$

Total saving in a year by replacing all 1500 rheostatic regulators/defective electronic regulator = $413 \times 1500 = \text{Rs } 619500/-$

Cost of providing regulator @200 = $200 \times 1500 = 300000/-$

Payback period = $300000/619500 = 0.48$ years say Six months

b. Replacing Existing Fans with Energy Efficient Fans

By replacing existing fans with energy efficient fans considerable saving in electricity consumption can be achieved.

One normal fan consumes around $75 \times 12 \times 200 / 1000 = \mathbf{180 \text{ KWH}}$

Energy efficient fan consumes around $12 \times 200 \times 50 / 1000 = \mathbf{120 \text{ KWH}}$

Saving per fan /year = $180 - 120 = \mathbf{60 \text{ KWH}}$

Saving in Rs = $60 \times 8.5 = \mathbf{\text{Rs } 510/-}$

Pay-back period = $1200/510 = \mathbf{2.35 \text{ Yrs i.e., 28 months}}$

It is proposed that 25 % of total fans i.e., 575 nos be replaced every year resulting in saving of Rs 293250/- with investment of Rs 690000/ (Cost/fan @1200/- as per EESL).

Payback 2 years

First very old fans/those which has been repaired be replaced.

Geysers

It has been observed that total 54 Nos 2000 W and one 3000W electric geysers have been installed for providing hot water in hostel bathrooms and mess respectively. Its operation cannot be controlled as same is required by students at various time slots of day being situated in hostel. It is proposed that 1500 Lts solar water heater be provided as detailed below. To ensure hot water supply even during cloudy or no bright sun light day Hybrid type Solar geysers with auto cut facility is proposed.

It has been assumed that geyser being used from Oct to March ie 6 months around 200 days in a year for 8 hrs per day.

- Annual Consumption of electricity by one geyser: $2000 \times 8 \times 200 = \mathbf{2880 \text{ KWH}}$
- Let with solar geyser electric geyser consumption is reduced by 90%
- Unit saved by each geyser will be = $2880 \times 0.9 = \mathbf{2592 \text{ KWH ie Rs } 22032/-}$
- Cost of 1500Lts Solar Geyser = $2,00,000 + 20000$ (pipe and fittings) = $\mathbf{2,20,000/-}$

Saraswati Hostel: No of inmates of 500 Nos and both boys' hostel 600 Nos.

Maximum total requirement of hot water @ 20 Lts/student assuming 75% students uses daily =
 $500 \times 20 \times 0.75 = 7500 \text{ Lts/day}$

Nos of 1500 LPD Solar Geysers required = **5 Nos**

Investment = $220000 \times 5 = 11,00,000/-$

Energy saving by installing Solar Geysers/yrs = $2592 \times 24 \times 8.5 = \text{Rs } 5,28,000/-$

Payback Period = $528000 / 1100000 = 2 \text{ years}$

CV Raman & RK Hostel Number of students in each boy's hostel 300Nos each

Maximum total requirement of hot water @ 20 Lts/student assuming 75% students uses daily =
 $300 \times 20 \times 0.75 = 4500 \text{ Lts/day}$

Nos of Solar Geysers Required = **3 each**

Cost of Energy saving by installing Solar Geysers/yrs = $2592 \times 30 \times 8.5 = 660000/-$

Investment = $220000 \times 6 = 13,20,000/-$

Payback period = $1320000 / 660000 = 2 \text{ years}$

Boys Mess: One 200 Lts hot water requirement is assumed. Which will cost around Rs 70000/-

- Annual Consumption of electricity by mess geyser: $3000 \times 8 \times 200 = 4800 \text{ KWH}$
- Let with solar geyser electric geyser consumption is reduced by 90%

Annual saving by solar geyser will be = $4800 \times 0.9 = 4320 \text{ KWH i.e., Rs } 36700/-$

Pay Back Period = $75000 / 36700 = 2.04 \text{ yrs say } 2 \text{ yrs}$

Total saving = $5,28,000 + 6,60,000 + 36,700 = 12,24,700/-$

Total Investment = $13,20,000 + 11,00,000 + 75,000 = 24,95,000/-$

It may please be noted that

Hot water produced by the solar heating system during the day is stored in an insulated storage tank. The insulation of the tank is such that water should remain hot without significant drop in temperature for around 24 hrs. Thus, water heated during the previous day should be available for use in the next morning.

Computers

Computers and monitors account for 30%-40% of the energy used by office equipment. Their energy consumption is second only to office lighting. It is estimated that a power managed computer consumes less than half the energy of a computer without power management.

There are 972 desk top computers and 11 laptops, and one server installed incampus. Apart from this there are 17 heavy duty printers and 23 normal printers.

Desktop on average consumes

Saving in this section can be attained by following measures

Replacing Desktop Computers by laptop:

A lot of it depends on the type of screen. A CRT (Cathode Ray Tube) screen consumes more than LCD (Liquid Crystal Display) screens. LCD screens can save up to 75% electricity over a CRT screen. A desktop also requires a UPS (Uninterruptible Power Supply) to keep it running during power loses which can eat significant amount of electricity. Laptops also have various other power management features. 70-80% of power consumption in a laptop is by CPU, and the rest of the components consume very less electricity. Laptops typically consume 20-50 Watts of electricity that can be trimmed down in power saver modes.

Desktop along with UPS normally consumes 200 W with CRT monitor and with LCD monitor it comes down to approx 100 W whereas Laptop power consumption is around 30 W.

If desktop is replaced with laptop, then assuming average use of 10 hrs for 300 days in a year saving calculations are as given below.

Power consumed by one desktop = $200 \times 300 \times 10 / 1000 = 600 \text{ KWH}$

Power consumed by laptop = $30 \times 300 \times 10 / 1000 = 90 \text{ KWH}$

Annual Saving by replacing one desktop = $600 - 90 = 510 \text{ KWH}$

If 20% i.e., 200 desktops are replaced every year then saving /year = $510 \times 200 = 102000 \text{ units/year}$

Yearly Saving in Rs = $102000 \times 8.5 = \text{Rs } 867000$

Monthly saving = $867000 / 12 = \text{Rs } 72250/-$

Cost of 200 laptops adjusting 10,000/salvage value of desktop = $25000 \times 200 = \text{Rs } 50,00,000/-$

So, payback period will be around 6 years.

However, it is recommended that whenever there is replacement / new purchase is required always go for Laptop.

Switching to a laptop may be a smart decision for someone who is concerned about how much energy a computer uses.

By Replacing Monitors:

If replacing desktop by Laptops is not possible due to cost factor replace all CRT and LCD monitors by LED monitors. Power consumed by different type of monitors is follows.

Typical 17" CRT	80 Watts
Typical 17" LCD	35 Watts
Typical 19" LED	20 Watts
Sleeping Monitor	0-15 Watts
Monitor Turned OFF	0-10 Watts

Other Measures:

Following measures by which considerable saving can be achieved.

1. Laptops are an additional 20 percent more power efficient when running on AC adapter power over battery power so always use laptops with AC adopter on.
2. On stand-by, the power consumption of both a desktop and a laptop computer falls to about a third.
3. Putting the monitor on stand-by reduces its consumption by 15%.
4. If the monitor is switched off completely, then of course it does not use power.
5. Switch off the loudspeakers if you are not using them.
6. Switch off the printer when it's not needed.
7. Switch off the screen if you are not working on the PC just now.
8. Switch off your computer or put it in stand-by mode if you are not going to work on your PC for more than 30 minutes. A multiple socket makes it easy to switch off all your computing equipment.
9. Switch off the modem at night.
10. One common misconception is that using a screensaver saves power, but this is not true

Air Conditioners

As per reports available from Maintenance staff out of total 265 Nos 1.5T ACs 25 are serviceable and 11 are unserviceable. Most of ACs other than 36 Nos 3star are very old and needs replacement which will increase cooling efficiency as well as considerable saving in electricity consumption.

Calculations and payback period by replacing one w/o star AC is as given below. It has been assumed Ac running hours daily as 8 hrs and period from April to Sept around 200 days.

Electricity consumed by one AC in a year = $2500 \times 8 \times 200 / 1000 = 4000 \text{ KWH}$

Energy consumed if replaced by 3-star AC = $1500 \times 8 \times 200 / 1000 = 2400 \text{ KWH}$

Saving in Units = **1600 KWH**

Saving in Rs = $1600 \times 8.5 = \text{Rs } 13600/-$

Cost of one 3 Star 1.5 T Ac= **27000/- for Window**

= 35000 for Split

Payback period = **2 years for Window and 2.5 Years for Split AC.**

Keeping in view heavy capital involved in replacing all at a time following is recommended:

- a. In first phase replace all repairable AC i.e., 36 Nos which will result in saving of 4.90 Lakhs in year. Even repairable AC should be replaced not repaired. Start replacement with criterion of oldest one first. Investment 10,80, 000/ assuming average cost @30000/-.
- b. Out of balance $229 - 36 = 193$ Nos, 40 be replaced every year resulting in saving of Rs 5.44 Lakhs every year with investment of 12,00,000/-.

Other Best Practices to save Energy in ACs:

Apart from above following routine maintenance practices and checks should be enforced to get maximum efficiency of existing ACs by periodic checking.

1. Insulation of room should be properly maintained by keeping all doors/ windows of AC rooms and check for any broken window glasses / door closure malfunctioning to prevent cold air to go out and hot air to go in.
2. AC should be switched on only 15 min before actual use and switched off while going out.
3. Normal air conditioning temperature should be kept not less than 24 degrees present BEE mandate. By thumb rule, increase in 1degree in indoor air temperatures can save 6% of electricity.
4. Room should have curtains on windows preferably dark colour.
5. If you are spending long hours in an air-conditioned room, try this tip. Keep it on for a couple of hours and then switch off for another one or two hours
6. Keep the ceiling/wall fan switched on when the AC is running. Together, they keep the room ventilated and circulate the cool air in all corners. Also, you will not have to keep decreasing the temperature.
7. All the dirt which gets accumulated in the ducts/filter and vents of the AC just make it work extra hard to ensure the cool air reaches your room. Regular cleaning of filters can lower an AC's energy consumption by 5-15 per cent! Plus, it saves the device from breaking down or in need of repair.

8. Most found defects leading to poor efficiency and consuming extra power are dirty air filters, thermostat not working, ice formation, water leakage, fan and swing not working. Ensure fort nightly checking of these points.

Other Low investment saving options:

1. Providing Master Switch outside every room will make it very easy for a person to switch off all appliances if someone forgets to switch off few appliances of room while leaving. This will save a lot of energy.
2. Providing motion sensors in toilets has big energy saving potential. Motion sensor will automatically switch on lights when there is any movement and switch off when no movement for few minutes. Two to three motion sensors be installed in each toilet as per size. In view of very low price of motion sensors it is highly recommended.
3. Regular Cleaning of fiber sheet provided in roof shed of workshop/ labs be ensured and few more opening in shed be provided, which will save considerable electricity being spent on lighting.
4. Regular cleaning of fans and exhaust fan blades be ensured otherwise efficiency will be compromised.
5. Harnessing Solar Power for Energy source substitution: I have been told that 25 KW solar plant in process of installation. But in my view there is very huge scope for solar power in SRMGPC as quite big chunk of consumption is during day hour only. Though there is huge variation in monthly energy consumption over period under study let us take 60000 KVAH as monthly consumption and assuming 50% ie 30000 KVA is consumed during day hour. It will come as 1000 units per day.

For generating 1000 KWH per day 250 KW Solar plant is required. Cost benefit analysis of same is as follows:

Units generated per year (10 months) = $30000 \times 10 =$ **300000 KWH**

Saving due to generated units = $300000 \times 8.5 =$ **Rs 25.5 Lakhs**

Monthly saving = **Rs 2.12 Lakhs**

Investment required @40000/KW = $250 \times 40000 =$ **Rs 100 Lakhs**

Accelerated Depreciation for 1st year= **Rs 40 Lakhs**

Accelerated Depreciation for 2nd year= **Rs 24 Lakhs**

Saving due to generated units in 2 years= $25.5 \times 2 =$ **Rs 51 Lakhs**

Return in two years = $51 + 40 + 24 =$ **Rs 115 Lakhs**

Payback period is less than 2 years

Chapter 7

Carbon Di-oxide Emission

In this Chapter we compute the CO₂ emissions.

For consumption of 1 Unit (1 kWh) of Electricity, the CO₂ emitted is 0.8 Kg. OR the Emission is 0.8 Kg/kWh. In the following Table we present the total units consumed and CO₂ emitted as under:

Month	KVAH	Carbon Emission in Tons
Jun-19	144807	116
Jul-19	85418	68
Aug-19	92012	74
Sep-19	146774	117
Oct-19	128476	103
Nov-19	88205	71
Dec-19	61774	49
Jan-20	60448	48
Feb-20	60765	49
Mar-20	60704	49
Apr-20	37055	30
May-20	25966	21
Jun-20	35957	29
Jul-20	68641	55
Aug-20	58432	47
Sep-20	41953	34
Oct-20	59483	48
Nov-20	48523	39
Dec-20	28606	23
Jan-21	29309	23
Feb-21	32736	26
Mar-21	40083	32
Apr-21	52307.4	42
May-21	22287	18

Table 8.1: CO₂ Emission

General Recommendations

In addition to the recommendations given above, a few more general ones are presented here. The savings due to their implementation could not be easily quantified, but their importance cannot be understated. Implementing all these measures will result in considerable saving without compromising much on the existing facilities and comforts.

- All Class Rooms, hostels, labs and common places to have Display Messages regarding optimum use of electrical appliances in the room like lights, fans, computers ,projectors etc.
- Most of the time, all the tube lights in a class room are kept ON, even though, there is sufficient light level near the window opening. In such cases, the light row near the window may be kept OFF.
- All appliances to be kept OFF or in idle mode if there will not be used for at least next one hour .
- All computers to have power saving settings to turn off monitors and hard discs, say after 10 minutes/30 minutes.
- The comfort air conditioning temperature to be set between 24°C to 26°C.
- Lights in toilet area may be kept OFF during day time
- Lighting • Photo sensors to be installed in central library to utilize optimum day lighting.
- street lights be fitted with day light sensors to minimize losses due to human error
- Split switching system to be adopted in inside corridors of Hostels and college building by clubbing alternate tube/ bulbs
- The heating load can also be reduced by reducing the consumption by other sources like lights, computers etc. and the occupancy needs to be considered. Explore the possibility of occupancy sensors.

Chapter 9

Way Forward:

Energy Management Cell

In order to streamline the use of energy in the campus and to ensure its efficient utilization, it is proposed following three possible energy management structures. A final decision on the type of energy management structure suitable for the institute should be taken by the Institute management.

- I. Appointment of an Energy Manager for the institute, with suitable experience and a proven track record. The person shall be responsible for the day to day energy conservation activities. New staff should be allotted to the Energy Manager or some staff members from Electrical Maintenance Section be made responsible to him/her. An annual review of the energy performance of the institute is to be performed and a certain percentage of the quantified savings be shared with the Energy Manager.
- II. Maintenance Head (Electrical) should himself take over the responsibility of ensuring efficient energy use on the campus. This will ensure prompt implementation of measures. This system may also require additional staff. A performance related incentive in the form of a bonus can be provided to the Electrical Maintenance staff based on savings achieved.
- III. Formation of an Institute level committee headed by the Senior Professor to review the implementation of energy conservation measures. All departments and section heads should submit a bi-annual report of compliance for review and action. Sections/ departments not achieving savings to be penalized and suitable incentives may be given to the performing departments. An annual review of the implementation of the energy saving measures should be taken up and performance should be monitored. A report of the same should be sent to the Director.
- Electrical energy consumption should be made a subject in the Institute budget with separate heads for departments and hostels. Energy performance can be a basis for providing incentives to hostels and departments.

Apart from implementing suggestions as per financial investment availability it is also suggested to get detailed Energy Audit Conducted for identifying energy guzzling equipments.